



CTO S.A.

Centrum Techniki Okrętowej S.A.
Ośrodek Certyfikacji Wyrobów
ul. Szczecińska 65, 80-392 Gdańsk
tel.: +48 58 307 45 28
e-mail: certyfikacja@cto.gda.pl



AC 170

CENTRUM TECHNIKI OKRĘTOWEJ S.A.

OŚRODEK CERTYFIKACJI WYROBÓW

NATIONAL CERTIFICATE OF CONSTANCY OF PERFORMANCE

No. 170-UWB-024

Pursuant to Regulation of the Minister of Infrastructure and Construction of 17th November 2016 r. on the methods of declaring construction products performance and the method of marking them with construction mark (Journal of Laws item 1966), this certificate refers to the construction product:

Smoke control doors of the ALUPROF[®] MB-45D system

intended for use as internal doors at residential construction, public investments and industrial premises

with the following smoke control classes:

S_w, S_m - acc. to PN-EN 13501-2+A1:2010 for single- and double- wings doors, with the wing with maximum dimensions (width x height) 1249 x 2429 mm, produced in compliance with item 1 of AT-15-5163/2016 Technical Approval

covered by technical approval:

AT-15-5163/2016

launched to trading under the name or trademark of manufacturer:

BOB-ROLLO Sp. z o. o.
ul. Młyńska 8
84-230 Rumia

and produced in the production plant:

BOB-ROLLO Sp. z o.o.
ul. Handlowa 25
81-061 Gdynia

This certificate confirms that all provisions resulting from the national system 1 concerning the assessment and verification of constancy of performance with respect to the performance of the product referred to in the abovementioned technical approval are applied and that the manufacturer has implemented a factory production control system to ensure the stability these properties.

This certificate, issued the first time on **21.04.2017**, remains valid until **29.12.2021**, provided that the technical approval, methods of assessment and verification of constancy of performance, the construction product itself and its manufacturing conditions will not change significantly and will not be suspended or revoked by the accredited product certification body.

Małgorzata Sulimierska

Head of Product Certification Division of CTO S.A.

Zbigniew Karpiński

President of Board – Managing Director

Gdańsk, 21.04.2017

Page 1/2

Product description:

Doors of the ALUPROF® MB-45D system, made of aluminium profiles have been designed as swing, internal doors, as single- or double-wing solution, glazed and with opaque infill.

The maximum dimensions of smoke control ALUPROF® MB-78EI system door in the clear of door frame (width x height):

- 1217 × 2418 mm in the case of single-wing doors; the maximum outer dimensions of the wing (width x height): 1249 × 2429 mm,

- 2100 × 2418 mm in the case of double-wing doors; the maximum outer dimensions of the wing (width x height) 1249 × 2429 mm.

Application:

Internal door of the ALUPROF® MB-45D system can be used are intended to close indoor openings at buildings.

Application conditions:

The doors shall be used in conditions, corresponding to class 2 of mechanical strength requirements, following the provisions of PN-EN 1192:2001, i.e., in light and medium performance conditions.

The validity of this certificate can be confirmed at www.certyfikacje.com.pl.